



P. O. Box, 787, 363, Bauddhaloka Mawatha, Colombo 7, Sri Lanka.
Telephone: 0094 011 2379800 Fax: 0094 011 2379850
120/4 A, Vidya Mawatha, Colombo 7, Sri Lanka.
Telephone: 0094 011 2379800 Fax: 0094 011 2379950

TEST REPORT

Report No. SS 1618691

Report to :

G. B. Coatings (Pvt) Ltd.,
No.700/10, Talangama North,
Battaramulla.

Issued By:

Materials Laboratory,
Industrial Technology Institute,
363, Bauddhaloka Mawatha,
Colombo 07.

2016-12-30

Page 01 of 03 Pages



TEST REPORT

Report No. SS - 1618691

Customer : G. B. Coatings (Pvt) Ltd., No.700/10, Talangama North, Battaramulla.	Test Item : Skim Coat Service Requested : Customer's letter dated 2016-12-14
Description : One (01) test item. Following information was given in the customer's letter. <ul style="list-style-type: none">Solakro Skim Coat - Exterior Rough Finish	Identification of Test Item: Test item was labelled as; Skim Coat White Exterior Rough Finish 1kg Date of Receipt of Test Item : 2016-12-16
Test Dates : From 2016-12-23 to 2016-12-29	

TEST RESULTS :

Test/ Unit	Test Method	Results	Requirements in ASTM C 475/C 475 M 02
Check cracking	ASTM C 474 : 05	Pass	No cracks in the thinner half of the wedge and no deep fissure cracks in the thicker half of the wedge.


Authorized Signatory
A.A.M.T. Adikari
Research Engineer
Materials Laboratory

2016-12-30
-/ss.,


Shashikala Liyanage
Technical Assistant